

DISTRICT LEVEL LABORATORY, CHAPRA (SARAN)
PUBLIC HEALTH DIVISION, CHAPRA

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES.

SAMPLE COLLECTED ON 15/12/2021 BY Mr. Akhilarant & RECEIVED IN THE LABORATORY ON 22/12/2021

Sp. No.	PARTICULARS OF THE SAMPLE				PARAMETERS EXAMINED (Value in mg/L except pH, otherwise mentioned)														
	Block	Gram Panchayat	Village	Name of the Nearest Person/ Institution	Turbidity	Colour	pH	Conductivity	Total Hardness	Total Alkalinity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Fluoride	T.D.S.	Arsenic
1.	Ekm		Hansojpur	Bhrihu Prabha Central School	1	—	7.3	498	164	172	40	14	23	15	0.1	0	0.2	272	BDL Neg.
Min-Max Permissible Limit (I.S. 10500/1983) 2012					10-25 NTU	12-50 HU	6.5-8.5	—	300-600	—	75-200	30-100	250-1000	150-400	0.3-1.0	45	0.6-1.5	500-1500	0.05-0.01

Remark: Analyzed parameters of above sample is good.

Memo No. 014/Chapra, Dated 24/12/2021
Copy forwarded to - Executive Engineer, P.H., Division, Chapra / A.E.
P.H. Sub. Div., Chapra/Masrakh/Sonpur/J.E. P.H.-Section.....

Signature of the Chemist
